

ਵਲੋਂ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਲਹਿਰਾਗਾਗਾ।

ਵਲ

ਪ੍ਰਿੰਸੀਪਲ,
ਪੰਜਾਬ ਪਬਲਿਕ ਸਕੂਲ,
ਪਿੰਡ ਖਾਈ (ਜਿਲ੍ਹਾ ਸੰਗਰੂਰ)।

ਨੰ: 230 ਮਿਤੀ: 28-12-2020

ਵਿਸ਼ਾ:- ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਲੈਣ ਸਬੰਧੀ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਆਪ ਦੀ ਮੰਗ ਅਨੁਸਾਰ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸਬੰਧੀ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ

ਨਿਰਧਾਰਿਤ ਪ੍ਰੋਫਾਰਮੇ ਤੇ ਆਪ ਨੂੰ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਲਹਿਰਾਗਾਗਾ।

ਪਿੱਠ ਅੰਕਣ ਨੰ:

ਮਿਤੀ:-

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ ਨੂੰ ਸੂਚਨਾ
ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।


ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਲਹਿਰਾਗਾਗਾ।

Building Safety Report

Name of School:- Punjab Public School, Village Khai, Tehsil Lehra District Sangrur

I have visited the above mentioned school building along with Sh Ravinder Pal Singh JE on 24-12-2020 and have visually inspected. It seems visually safe subject to the following observation & conditions.

- a) Parameters to check the stability and safety of building such as Architectural Drawings, Bearing capacity, Foundation detail, Structural Drawings, Technical Specifications. Test Reports of Material used Quality Control reports and certificate from Engineer in Charge for construction are not available.
- b) In case of any addition, alteration or expansions and modification to this building are done; certificate may be re-obtained after completion from undersigned.
- c) In case the building is affected by flood or if there is settlement of walls/ foundation or sagging of roofs etc., immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) A separate certificate regarding Fire Fighting should be obtained from the competent authority.
- e) A separate certificate regard Electrical Works should be obtained from the competent authority.
- f) The owner of the building/ Management is fully responsible regarding safety of building from all angels in spite of this report.
- g) The covered area of the building is 17921 Sq. Ft.
- h) This Report is not valid for legal purpose.
- i) This building visually seems safe to occupy for the normal use up to: 31-03-2025


Sub-Divisional Engineer
Const. Sub-Divn. PWD B&R
Lehragaga 